



September 16, 2021

Intertek Project Number: G104670214
Letter Report Number: 104670214LEX-002JLeviton Network Solutions Europe
Viewfield Industrial Estate
Glenrothes, Fife, KY6 2RS, United Kingdom

Subject: Testing Conformity Letter for Configuration 10 – Category OS1a / OS2 – MPO(MTP) cassettes – LC-PC connectors ended- HDX Enterprise LL.


Dear Client:

This letter report was written to inform you of the test results for Configuration 10 – Category OS1a / OS2 – MPO(MTP) cassettes – LC-PC connectors ended- HDX Enterprise LL. The product was **compliant** with the calculated criteria of ISO/IEC 11801-1:2017 Information technology - Generic cabling for customer premises - Part 1: General requirements Section 6.5.2.1 as well as the calculated criteria of Leviton for their own products.

Table 1: Parts List

Part number	Description	Qty
VPC-S2D1LCLC0300	Duplex, OS2 Yellow, 1.6 mm LC/UPC-LC/UPC, 30.0 Metres	12
U1LSM1-UNN	HDX Enterprise MTP Cassette, (0.90dB), 12-fiber OS2, LC Shuttered (Blue) to 1x12-fiber MTP (male), Universal Polarity, Black Latch	2
FT-AD012LL100005C05CN-NNBS	Enterprise DC Low Loss Fiber Trunk 12-Fiber OS2 Singlemode Yellow 100.0 metres Euroclass Cca, Method B, 0.5m Straight Tails with 12-Fiber Female MTP LL 0.35db connectors to 0.5m Straight Tails with 12-Fiber Female MTP LL 0.35db connectors, Standard Labelling, No Pulling Eye	1
5FUHD-6MP	HDX MTP Adapter Plate, 3 duplex adapters, key-up/key down	1
FT-AD012KL160005C05CN-NNBS	Enterprise DC Low Loss Fiber Trunk 12-Fiber OS2 Singlemode Yellow 160.0 metres Euroclass Cca, Method B, 0.5m Straight Tails with 12-Fiber Male MTP LL 0.35db connectors to 0.5m Straight Tails with 12-Fiber Female MTP LL 0.35db connectors, Standard Labelling, No Pulling Eye	1

A full description of the test methods, test configurations, and detailed test results was included in the final Intertek report 104670214LEX-001.1, issued 8/13/2021. If you have any questions, please feel free to call us at 1-800-788-3061.

Prepared By:  Date: 9/16/2021
Paul Alt, Senior Project EngineerApproved By:  Date: 9/16/2021
Richard Proctor, Engineering Manager