



September 16, 2021

Intertek Project Number: G104670214  
Letter Report Number: 104670214LEX-002MLeviton Network Solutions Europe  
Viewfield Industrial Estate  
Glenrothes, Fife, KY6 2RS, United Kingdom

Subject: Testing Conformity Letter for Configuration 13 – Category OM4 – MPO(MTP) cassettes – LC-PC connectors ended- HDX Unity ULL.

Dear Client:

This letter report was written to inform you of the test results for Configuration 13 – Category OM4 – MPO(MTP) cassettes – LC-PC connectors ended- HDX Unity ULL. The product was **compliant** with the calculated criteria of ISO/IEC 11801-1:2017 Information technology - Generic cabling for customer premises - Part 1: General requirements Section 6.5.2.1 as well as the calculated criteria of Leviton for their own products.

**Table 1: Parts List**

Part number	Description	Qty
LPC-M4D1LCLC0300	ULL Duplex, OM4 Heather Violet, 1.6 mm LC/UPC-LC/UPC, 30.0 Metres	24
41GSM4-UNN	HDX Unity MTP Cassette, (0.35dB), 12-fiber OM4, LC Shuttered (Heather Violet) to 1x12-fiber MTP (male), Universal Polarity, Black Latch	2
42GSM4-UNN	HDX2 Unity MTP Cassette, (0.35dB), 24-fiber OM4, LC Shuttered (Heather Violet) to 2x12-fiber MTP, Universal Polarity, Black Latch	1
FTU-FG024LL030005C05CN-NNBS	Unity Ultra Low Loss Fiber Trunk 24-Fiber OM4 Multimode Heather Violet 30.0 metres Euroclass Cca, Method B, 0.5m Straight Tails with 12-Fiber Female MTP UL 0.20db connectors to 0.5m Straight Tails with 12-Fiber Female MTP UL 0.20db connectors, Standard Labelling, No Pulling Eye	1

A full description of the test methods, test configurations, and detailed test results was included in the final Intertek report 104670214LEX-001.1, issued 8/13/2021. If you have any questions, please feel free to call us at 1-800-788-3061.

Prepared By:  Date: 9/16/2021  
Paul Alt, Senior Project EngineerApproved By:  Date: 9/16/2021  
Richard Proctor, Engineering Manager