



# Attestation of Conformity

## Screened Class EA / Category 6A ISO/IEC, EN & ANSI/TIA Four Connector Channel

**Leviton Manufacturing UK Ltd.  
Viewfield Industrial Estate, Glenrothes,  
KY6 2RS Fife, United Kingdom**


**Attestation of Conformity No. 0473-3P-1241049**

*This type of Class EA / Category 6A Screened Four Connector Channel has been tested by 3P Third Party Testing. The testing has shown compliance with the Class EA electrical performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018 and the Category 6A electrical performance requirements of ANSI/TIA-568.2-D:2018 incl. appendix 1 and 2. The Attestation of Conformity is valid for the actually tested channel sample at the time of testing. The positive observations and test results that are the basis for this Attestation of Conformity, are relevant only to the tested sample and do not imply that the product is, or has ever been, under a 3P maintenance programme.*

Cables:	Horizontal Cable (80 m), Qualification Status:	P/N AC6S/FTP-B2ca- Manufacturer verified
Conn. Hardware:	Modular Jack, Qualification Status:	P/N AX6AS Manufacturer verified
Consolidation Cord:	(5 m) Modular Jack, Qualification Status:	P/N AC6-DCZ-B2ca- P/N AX6AS Manufacturer verified
Patch and equipment Cords:	(2 m, 3 m, 5 m) Qualification Status:	P/N AC6PCG* Manufacturer verified

*\* denotes variable length, colour and packaging*

Hoersholm, 27 August 2024

  
Peter Freiberg Kaas  
Test Responsible

**3P Third Party Testing ApS**  
Agern Alle 3  
2970 Hørsholm  
Denmark

<https://www.3ptest.dk/>

*Independent Testing - For End User Confidence*

Hoersholm, 27 August 2024

  
Jens Rytter Petersen  
General Manager

Page 1 of 1